



1 **EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC**

3 EC - Type Examination Certificate Number: **Baseefa09ATEX0187X**

4 Equipment or Protective System: **ASG XXX Range of Cable Glands**

5 This certificate is held by: **Abtech Limited**

6 Address: **Sanderson Street, Lower Don Valley, Sheffield, S9 2UA**

7 This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 Baseefa, Notified Body number 1180, in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No. GB/BAS/ExTR09.0126/00

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN 60079-0: 2006, EN 60079-1: 2004, EN 60079-7: 2006, IEC 61241-0: 2004, IEC 61241-1: 2004**

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

11 This EC - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.

12 The marking of the equipment or protective system shall include the following :

**⊕ II 2GD Ex d IIC Ex e II Ex tD A21 IP66/IP67 (- 60°C ≤ ta ≤ + 80°C)**

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa Customer Reference No. 6376

Project File No. 09/0435

This certificate is granted subject to the general terms and conditions of Baseefa. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

**Baseefa**

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa Ltd  
Registered in England No. 4305578. Registered address as above.

*RS Sinclair*  
*RS Sinclair*  
PP R S SINCLAIR  
DIRECTOR  
On behalf of  
Baseefa



13

## Schedule

14

Certificate Number Baseefa09ATEX0187X

### 15 Description of Equipment or Protective System

#### The ASG XXX RANGE OF CABLE GLANDS

The ASG XXX Range of Cable Glands is intended for use with an effectively filled and circular cable and comprises the following components, the metal parts of which can be manufactured in brass and may be nickel plated to suit the application:-

- a. An entry component, in the size range (M16 to M90)
- b. A displacement sealing ring
- c. A metal compression ring
- d. A liner bush
- e. A compression nipple

The XXX is used to define the size of gland e.g 20a or 25 etc.

#### Variation 0.1

Substitution of the M20 to M90 entry component with an entry component having an NPT equivalent in the range 1/2" NPT to 3" NPT.

### 16 Report Number

GB/BAS/ExTR09.0126/00

### 17 Special Conditions for Safe Use

1. These glands are suitable for use within an operating temperature range of -60°C to +80°C.
2. When the gland is used for increased safety or dust protection, the entry thread shall be suitably sealed, in accordance with EN 60079-14, to maintain the ingress protection rating of the associated enclosure.
3. Glands are only suitable for fixed installations, the cable for which must be effectively clamped to prevent pulling and twisting.
4. When used in flameproof applications on braided or armoured cable the seal within the gland must seal onto the inner sheath of the cable, i.e. that which is under the braid or armour and not on the outer sheath that covers the braid or armour.

### 18 Essential Health and Safety Requirements

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

### 19 Drawings and Documents

Number	Issue	Date	Description
ABT20089	A	02/07/09	Certification marking – ASG cable glands
Baseefa08ATEX0011X	--	25/01/08	A2F-S-XXX Range of Cable Glands